

BRINE CORROSION INHIBITOR - 777044

Testing and Control

Control 777044 as Boron at 70 - 100 ppm by laboratory test.

Note: Because the specific gravity of the brine varies with concentration, the resulting level of boron should be calculated as follows:

$$\frac{\text{mg/L Boron}^*}{\text{SG of the Brine}} = \text{ppm Boron}$$

Fig.1 CaCl₂ brine specification gravity at 20 Deg C

